



Las Vegas Convention Center, Las Vegas, Nevada
Exhibit Days: November 1 – 4, 2011
Education Days: October 31 – November 4, 2011

LIGHTING RESTRICTIONS

Booth elements must be established and maintained within the officially contracted confines of your exhibit space and not protrude into the aisles. This includes all truss work, lighting apparatus, projection equipment, signage, screens, etc.

- Due to weight and power restrictions, truss lighting is limited in some exhibit areas.
- Strobe lights are not permitted.
- Lighting should be directed to the inner confines of the booth space and must not project onto other exhibits, show aisles or any other area outside the booth space.

Las Vegas Convention Center - Halogen Lighting Policy

To ensure the safety of building customers at the Las Vegas Convention Center, the building has placed a ban on certain halogen lamps. Halogen lamps are limited to 75 watts and must be of the sealed variety, which prevents direct handling of the bulb. Below are details on halogen lighting and examples of what is and is not permitted.

LAS VEGAS CONVENTION AND VISITORS AUTHORITY HALOGEN LAMP RESTRICTION

What halogen lighting IS covered by this policy?

This policy covers only certain restrictions on stem- and track-mounted halogen lighting installed by display contractors and exhibitors for the temporary lighting of exhibit booths. Stem-mounted fixtures employ an arm that extends outward from the mounting mechanism, which is typically terminated in a light head that pivots, swivels or is otherwise movable. The use of stem- and track-mounted halogen or other fixtures employing either a linear halogen bulb (figure 1) or a non-shielded halogen bulb (figure 2) is not allowed (see photos below).

What halogen lighting is NOT covered by this policy?

Halogen bulbs or lighting fixtures (including track lighting) containing halogen bulbs that are being displayed or demonstrated as part of an exhibiting company's product line or business in its booth. Theatre, stage or studio lighting equipment utilizing halogen lamps may be used only for code-defined theatre or stage activities. Such lighting may not be used as booth lighting or to illuminate signs or objects neither on the exhibit floor nor in any other exhibit or meeting area where the general public has access.

How do the restrictions affect stem- and track-mounted halogen light fixtures?

Unless otherwise stated in this policy, stem- or track-mounted halogen light fixtures installed in LVCVA facilities must:

1. Utilize one of the halogen bulb styles shown in figure 3 (see photos below). These bulbs have an additional glass shield that is integrated with the bulb design and require no other shield as part of the light fixture; and
2. Utilize a bulb not exceeding the listed wattage permitted for use by the fixture manufacturer, but in no case exceeding 75 watts.

DISAPPROVED HALOGEN BULBS



Figure 1 Linear Bulbs



MR 11/16 Uncovered



Line Voltage



Low Voltage Bi-Pin

Figure 2 Non-Shielded Bulbs

APPROVED HALOGEN BULBS – 75 watts max



– low voltage

MR 11/16



Covered



MR 16 Covered – line voltage

Figure 3. Self-Shielded Bulbs
